



Date of Issue: 5/23/2023
 Report Number: 23-001602
 Revision Number:1
 Date Order Received: 05/15/2023

For the Account of: Mermet
 5970 N Main St Cowpens SC 29330

Client's Identification: E SCREEN 10 PERCENT

CERTIFICATE OF TESTING

TEST PERFORMED: California Fire Marshal Title 19: Section 1237 Small Scale Test – Interior Materials Qualifications (Proposed Revision – 8/9/93)

TEST RESULTS

Specimen	Afterflame (s)	Char Length (in)
1	0.0	3.5
2	0.0	4.0
3	0.0	4.0
4	0.0	3.5
5	0.0	3.0
Avg. Warp	0.0	3.6
Specimen	Afterflame (s)	Char Length (in)
1	0.0	3.0
2	0.0	3.0
3	0.0	3.5
4	0.0	3.5
5	0.0	3.0
Avg. Fill	0.0	3.2

Fabric Weight (oz / sq.yd.): 10.4

Tested:

- Initially
- After Laundering
- After Dry Cleaning

ACCEPTANCE CRITERIA

1. Average Flame Time (after flame) after removal of the flame source may not exceed **4.0 seconds** for length or width
2. Char length may not exceed **6.0 inches** for any individual specimen.
3. When a part of the char length is melt away due to heat from the flame source and not from propagating flame, the sample submitted meets the requirements of Title 19 - California Code of Regulations, Section 1237 and 1237.1 for fabrics weighing less than 4 oz./sq.yd. These specimens shall be marked with an asterisk (*) next to the char length.

CONCLUSION

Based on the above Results and Acceptance Criteria, the item tested:

- Complies
- Does Not Comply

CERTIFICATION I certify that the above results were obtained after testing specimen in accordance with the procedures and equipment specified by the standard stated above.

Berta Stiver

Authorized Signature

Date Order Completed: 05/18/2023